

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No.F.6/DFS/MS/School/2021/SZ / 547


Dated: 28/7/21

FIRE SAFETY CERTIFICATE

Certified that the **Gyan Deep Public School**, Mundhela Khurd, New Delhi-110073 comprised of ground floor plus one upper floor owned/occupied by Gyan Deep Public School was issued Fire Safety Certificate by this department vide letter No F.6/DFS/MS/School/2017/SZ/1771 dated 08/12/2017. The school building was re- inspected by the officer concerned of this department on 15/07/2021 in the presence of Sh. R.S Sehrawat (Manager) and found that the School building have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the building/ premises is fit for occupancy class 'Educational' w.e.f. the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed as under.

Issued on at New Delhi.

28/7/21


(Sunil Chawdhary)
Dy. Chief Fire Officer

Copy to:-

1. The Manager,
Gyan Deep Public School,
Mundhela Khurd, New Delhi-110073
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.